

SITE PLAN SCALE - 1CM : 2.5M		SITE BOUNDARY FIRE WORKS SHOP 15 M SAFETY DISTANCE	
BLOCK 3 FIREWORKS SHOP PARTY SITE S.NO.55/1A1A BLOCK 2 FIREWORKS SHOP BLOCK 1 FIREWORKS SHOP VACANT LAND VACANT LAND VACANT LAND VACANT LAND VACANT LAND			
UNDERTAKING:- "ALL THE RELEVANT PROVISION UNDER THE EXPLOSIVES RULES, 2008 PERTAINING TO THE LICENCE IN FORM LE-4 AND CONDITIONS OF THE LICENCE(S) ARE SCRUPULOUSLY COMPLIED WITH"		AREA OF SITE : 990.294.sq.m(9593.125.sq.ft) AREA OF PROPOSED SHOP G.F : 28.46.sq.m(308.235.sq.ft) SHOP 1 G.F : 24.97.sq.m(268.777.sq.ft) SHOP 2 G.F : 24.97.sq.m(268.777.sq.ft) TOTAL AREA : 78.39.sq.m(843.786.sq.ft) AREA OF VACANT : 911.904.sq.m(9739.336.sq.ft)	
ALL DIMENSIONS ARE IN METTER SCALE 1:100			
SCHEDULE OF JOINERIES:- R.S.M.D - ROLLING SHUTTER - 1.83 X 2.10M (IF ROLLING SHUTTER DOOR IS PROVIDED) R.S.I.E.E.D - ROLLING SHUTTER - 1.20 X 2.10M (THERE SHALL BE HINGES PROVIDED AT THE TOP OF THE SHUTTER DOOR TO LOCK THE SHUTTER LEAF IN OPEN POSITION AND INTER LOCK ON THE ROLLING DOOR TO AVOID FALL DOWN.)		S.H. CONSTRUCTION Ground floor, commercial complex Allanpettai water tank Virodhunagar. cell.-#916438950962 Drawn by: Checked by J.Pradheesh. Date:09.03.2024 Sheet-A2 Email: shah@shconstruction@gmail.com	
NOTE : 1. THERE IS NO ANY OTHER FIRE WORKS SHOP ,IN FLAMMABLE HAZARDOUS MATERIALS SHOP AND WITH IN THE RADUIS OF 15 METRES 2. THERE ARE NO STAIR CASE IN THE PREMISES OF BUILDING 3. 2NO'S .10KGS D.C.P FIRE EXTINGUISHERS WILL BE PROVIDED 2NO'S WATER BUCKETS WILL BE PROVIDED 2NO'S SAND BUCKETS WILL BE PROVIDED 4. ELECTRICAL FITTINGS ARE CONCEALED 5. POLICE STATION - AMATHUR - 12.0 KMS FIRE SERVICE STATION - SVAKASI - 14.0 KMS RAILWAY STATION - THIRUTHANGAL - 7.0 KMS 6. TECHNICAL PERSONS - 3 NOS 7. ELECTRICAL CIRCUIT BREAKER IS PROVIDED OUT SIDE OF THE BUILDING 8. FIRE WORKS SHOP TO SVAKASI BUS STAND - 20 KMS 9. THERE IS NO L.T.&I.T ELECTRICAL LINE IS PASSING OVER THE FIRE WORKS SHOP 10. ALL THE RELEVANT PROVISIONS UNDER THE EXPLOSIVES RULES 2008 AND CONDITION OF THE LICENCE ARE FOLLOWED 11. NO COURT CASE/LITUATION IS PENDING IN THE COURT OF LAW 12. EDUCATIONAL INSTITUTES (OR) HOSPITALS & DIAGNOSTIC CENTERS, RELIGIOUS PREMISES, BANK, SHOPPING MALL SHALL BE INSERTED OR SITUAATED AT ABOVE 15M RADUIS. CAPACITY: FIRE WORKS - 100KG/S CHORSA CRACKERS & OR SPARKLERS - 600XG/S CLASS - 7 , DIVISION - 2 , SUB - DIVISION - 1 & 2, 600XG/S			
FOR			
NOMINEE & AUTHORIZED SIGNATORY			
APPLICANT		ENGINEER	