

22-01-2025
Bengaluru


STABILITY CERTIFICATE

It is certified that the proposed construction [(basement+ stilt+ 7 floors) IT building at plot no. 170/a & b, development plot industrial Estate, 2nd main road and estate main road, Palavakkam, chennai, at s.no. 140/19a, palavakkam Village, sholinganallur taluk, greater Chennai Corporation, zone-14, div – 185] is designed to resist earthquake. Check has been made and found safe and I hereby certify that:

1. The minimum grade of concrete is M30.
2. The design and analysis using the code of practice for plain and reinforced concrete as per IS 456, Design Loads as per relevant IS, wind loads as per IS 875 part 3 and Design of Earthquake resistant Structure as per IS 1893 –2016 are carried out.

The building will be safe and sound when used for the purpose for which it is designated.

This certificate is invalid, if any subsequent modifications are made to the structure in any manner. Further the certificate is invalid In the case of misrepresentation of data, suppression of records or wilful modifications to records by the builder or their agents.



Structural Engineer (V.G.Palaksha)
CMDA Reg. No. SE/GR-1/19-06-149

V.G. PALAKSHA, M.E.(STR)
Structural Consultant
CMDA Reg. No. SE/GR-I/19/06/149
1696/5, 6th Cross, Dr. SRK Nagar
MCECHS Layout, Jakkur
Bangalore-560 064, Mob: 9972097980

COVE HOLDINGS PVT LTD

Amer & Ani Architects

**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP

Structural Design Philosophy For COVE IT BUILDING, Chennai

V.G. PALAKSHA, M.E.(STR)
Structural Consultant
CMDA Reg. No. SE/GR-I/19/06/149
1696/5, 6th Cross, Dr. SRK Nagar
MCECHS Layout, Jakkur
Bangalore-560 064, Mob: 9972097980

Revision Index

Revision	Date	Reason for revision
R0	08.08.2023	GFC

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 1 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD



DESIGN PHILOSOPHY FOR STRUCTURAL DESIGN

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP

Contents

1.0 GENERAL INFORMATION	3
2.0 PROJECT BRIEF	4
2.1 PROJECT DESCRIPTION.....	4
2.2 BUILDING DESIGN DATA.....	4
3.0 STRUCTURAL DESIGN CRITERIA.....	4
3.1 DESIGN BRIEF:.....	4
3.2 BASIC ASSUMPTION	5
3.3 LIMIT STATE METHOD OF DESIGN	6
3.3.1 LOAD COMBINATIONS	6
3.3.2 SERVICEABILITY CHECK	7
3.3.3 COMPUTER ANALYSIS.....	7
3.4 DESIGN LOAD DATA	8
3.4.1 DEAD LOADS – IS 875: PART 1	8
3.4.2 LIVE LOADS– IS 875: PART 2.....	9
3.4.3 WIND LOAD – IS:875 PART 3	10
3.4.4 SEISMIC LOAD:	10
3.5 CONSTRUCTION MATERIALS.	11
3.5.1 STEEL	11
3.5.2 CONCRETE	11
3.5.3 LAP / DEVELOPMENT LENGTH.....	12
3.5.4 CONCRETE COVER.....	13
3.5.5 SEPERATION JOINTS	13
3.6 GENERAL NOTES	13
3.7 DESIGN CODES AND REFERENCES:.....	14

V.G. PALAKSHA, M.E.(STR)
Structural Consultant
CMDA Reg. No. SE/GR-I/19/06/1499
1696/5, 6th Cross, Dr. SRK Nagar
MCECHS Layout, Jakkur
Bangalore-560 064, Mob: 9972097980

File Name: Structural Design Philosophy		Project No: APC/22-23/4		Page Number: 2 of 15	
Prepared by	YOGESH	Checked By	PAL	Approved By	VGP



Amer & Ani Architects

COVE HOLDINGS PVT LTD

DESIGN PHILOSOPHY FOR STRUCTURAL DESIGN

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP

1.0 GENERAL INFORMATION

NAME OF PROJECT : COVE IT BUILDING

LOCATION OF PROJECT : CHENNAI

NAME OF OWNER : COVE HOLDINGS PVT LTD

NAME AND ADDRESS OF ARCHITECTS : Amer & Ani Architects
#14, 32nd Cross St, Tiruvalluvar Nagar,
Besant Nagar, Chennai,
Tamil Nadu -600090.

NAME AND ADDRESS OF CONSULTANT : Anagha Prudent Consultants LLP
#114-A, CIL Layout, 2nd Cross,
3rd Main, Sanjaynagar
Bangalore – 560 094, India
Telephone: +91-80-41313961,
www.anaghaprudent.com

V.G. PALAKSHA, M.E.(STR)
Structural Consultant
CMDA Reg. No. SE/GR-I/19/06/149
1696/5, 6th Cross, Dr. SRK Nagar
MCECHS Layout, Jakkur
Bangalore-560 064, Mob: 9972097980

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 3 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP**2.0 PROJECT BRIEF****2.1 PROJECT DESCRIPTION.**

Cove IT Building are proposed to construct IT buildings at Chennai.

The proposed development consists of commercial building. It consists of Basement + Stilt + 7 Floors +Terrace. Basement and Stilt are used for car parking. ITES units starts from first floor to 7th floor.

2.2 BUILDING DESIGN DATA.

The details of the IT Building to be constructed are as follows.

Sr. No	NAME	Approx. Size		Description	No of Floors	Design Consideration
		L (mtr)	W (mtr)			
1	IT Building	37	30	Multiple floors RCC FLAT SLAB structure	1B+1S+7+T	1B+1S+7+T

The IT Building development consists of Basement + Stilt + 7 Floors +Terrace.

Height of typical Floor is 3600mm and Stilt is 4700mm.

3.0 STRUCTURAL DESIGN CRITERIA**3.1 DESIGN BRIEF:**

The material chosen for the structural elements in the building is reinforced concrete. Concrete is homogeneous in nature with good strength for compressive forces. Concrete also has a good resistance to fire and weather.

Flat Slab system is proposed for the proposed IT Building. Columns will be arranged in basements, typical floors based on functional and economical considerations for supporting of above floors. Columns are used in resisting lateral loads caused by Wind and Earthquake.

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 4 of 15

Prepared by YOGESH

Checked By PAL

Approved By

VGP

V.G. PALAKSHA, M.E.(STR)
Structural Consultant
CMDA Reg. No. SE/GR-I/19/06/149
1696/5, 6th Cross, Dr. SRK Nagar
MCECHS Layout, Jakkur
Bangalore-560 064, Mob: 9972097980

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN****Document No: ANAGHA/CIB****Date: 08.08.2023****R0**

The grade of concrete shall be as per Design requirement & Reinforcement steel shall be with a yield stress of **500 N/mm²**. Also lean concrete with strength of 10 N/mm² (M-10) shall be used for levelling course.

Columns shapes shall be rectangular and the sizes shall depend upon the detailed analysis & design, considering the optimum utilization of steel & concrete.

SUPER STRUCTURE:

Super structure of the building is Flat slab, beam system with columns, shear and lift cores as RCC walls. The beams are arranged based on architectural requirement. Continuity of slabs are considered wherever possible for design of slabs.

Slab thickness 285mm and 525mm thick unless mentioned otherwise as per shown in drawing.

SUB STRUCTURE:

Sub structure consists of pile foundation, which distributes gravity loads & lateral loads from super structure to soil beneath as recommended from soil investigators.

3.2 BASIC ASSUMPTION

1. The building shall be designed as one rigid monolithic structure.
2. Sizes of structural elements have been provided for optimal design of maximum stress.
3. Load carrying capacity of compression members increases with higher grade of concrete mix. Therefore to achieve economy and reduced size of columns, shear wall, higher grade of concrete is proposed.
4. Grade of concrete for beams and slabs where flexural strength shall be basis of design, grade M-30 concrete shall be proposed.
5. Continuity of structural members is very much desirable since it will provide multiple path of load resistance. Therefore as far as possible all parts of building are tied together to act as one unit in resisting external forces.

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 5 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB



Date: 08.08.2023

R0

6. The floor slabs shall be considered as horizontal diaphragms and stiff enough in their planes to produce equal lateral displacement of all shear walls at a given floor level.
7. Non-linear analysis considered for analysis involving super-position of actions and displacements.
8. The cladding and other non-structural components do not influence the behaviour of the building against lateral loads.
9. The out of plane action of slabs are disregarded for lateral load analysis.

3.3 LIMIT STATE METHOD OF DESIGN

Limit state method of design has become common method. In view of this, all structural elements of the building shall be designed with "LIMIT STATE METHOD" as per Indian standards.

3.3.1 LOAD COMBINATIONS

The following load Combinations shall be used for the structural load analysis

Load Combinations		Remarks
1.5 (DL+LL)		DL = Dead Load on the Structure LL = Live Load on the structure RSPX = Earthquake Load along X direction RSPY = Earthquake Load along Y direction WX = Wind Load along X direction WY = Wind Load along Y direction
1.5 (DL+ RSPX)	1.5 (DL $\pm$ WX)	
1.5 (DL $\pm$ RSPY)	1.5 (DL $\pm$ WY)	
(0.9 DL $\pm$ 1.5 RSPX)	(0.9DL $\pm$ 1.5 WX)	
(0.9 DL $\pm$ 1.5 RSPY)	(0.9DL $\pm$ 1.5 WY)	
1.2 (DL+ LL $\pm$ RSPX)	1.2 (DL+ LL $\pm$ WX)	
1.2(DL + LL $\pm$ RSPY)	1.2 (DL+ LL $\pm$ WY)	

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 6 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP**Load Combinations for Limit State of Serviceability**

1.0 (DL+LL)	
1.0 (DL $\pm$ RSPX)	1.0 (DL $\pm$ WX)
1.0 (DL $\pm$ RSPY)	1.0 (DL $\pm$ WY)
DL + 0.8 (LL $\pm$ RSP X)	DL+0.8(LL $\pm$ WX)
DL + 0.8(LL $\pm$ RSPY)	DL + 0.8(LL $\pm$ WY)

3.3.2 SERVICEABILITY CHECK

This is given with following limitations:

- a. For Vertical deflections : Total load deflections = Span / 250
- b. Lateral drift of Structure(wind) : = Height / 500
- c. Storey drift = 0.004H*
- where H = total height of the building
H* = storey height
- d. For Cracking
1. For water retaining structure = cracked section,
limiting crack width to 0.2 mm

3.3.3 COMPUTER ANALYSIS

All structures shall be analyzed using STAADPro Software / ETABS / SAFE and RCDC.

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 7 of 14

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB



Date: 08.08.2023

R0

3.4 DESIGN LOAD DATA

The RCC/Basic frame structure shall be designed considering the dead loads of the following elements.

WALLS

External walls 200mm

Internal walls 200mm

SUNKEN SLAB

Toilet Sinking 150 mm

Balcony Sinking 100 mm

Utility Sinking 150 mm

Toilet filling material PCC

O.H. WATER TANKS

The R.C.C. over head water tank shall be considered for Potable /Fire & Raw water storage at locations as per MEP consultants. Capacity of tanks considered based on input from MEP consultants.

3.4.1 DEAD LOADS – IS 875: Part 1

The densities of different materials considered for design are as follows:-

Density of reinforced concrete	25 kN/ cu.m
Density of soil	18 kN/ cu.m
Density of steel	78.5 kN/ cu.m
Density of plain concrete	24 kN/ cu.m
Density of finishes / plaster for walls	20.4 kN/ cu.m
Density of Granite	26 kN/ cu.m
Density of solid blocks	21 kN/ cu.m

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 8 of 14

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD

Amer & Ani Architects

**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
 Prudent Consultants LLP

Density of Cinder for filling	8 kN/ cu.m
Density of Brickbat filling	20 kN/ cu.m
Floor finishes	2.4 kN/sq.m
Terrace level floor finish	2.4 kN/sq.m
Car parking level floor finish	2.4 kN/sq.m
Curtain wall glazing	0.90 kN/sq.m

3.4.2 LIVE LOADS— IS 875: Part 2

The LIVE loads recommended herein is for UDL (Uniformly Distributed Load) over the Floor.

1. Staircase - 4.0 KN/ m²
2. Corridors, Balconies - 3.0 KN/ m²
3. Toilet Floor - 4.0 KN/ m²
4. Terrace Floor - 2.0 KN/ m²
5. Lift Machine slab - 12.0 KN/ m²
6. Fire Driveways - 45.0 MT WAGON Load (a unifomly distributed load of 15.0 KN/m² is assumed on the slab as equivalent load)
7. Podium slabs - For landscape filling as per Landscape drawings.
8. Gym area - 5.0 KN/ m²
9. Car parking - 3 KN/ m²
10. Indoor Games - 3.0 KN/ m²
11. Party Hall - 5.0 KN/ m²
12. Lift Lobby - 4.0 KN/ m²
13. Electrical Room - 7.5 KN/m²

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 9 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD



DESIGN PHILOSOPHY FOR STRUCTURAL DESIGN

Document No: ANAGHA/CIB

Date: 08.08.2023

R0



3.4.3 WIND LOAD – IS:875 Part 3

As per IS.875 part 3 2015 Basic wind speed in Chennai is considered as **50 m / sec.**

Risk Coefficient K1	: 1.00 (k1 corresponds to 50 years Mean Probable Design Life of Structure)
Terrain, height, structure size factor K2	: It varies wrt height from 1 to 1.2 (To suit the height of the structure for terrain Category 4 is considered)
Topography factor K3	: 1.13
Importance factor K4	: 1.00
Design wind speed Vz	: $V_b \times K1 \times K2 \times K3 \times K4$

3.4.4 SEISMIC LOAD:

1. Sesmic loads shall be calculated as per IS 1893-(Part 1) - 2016.
2. According to the IS: 1893, the Indian Sub-Continent has been divided into four seismic zone. Zone II is zone of "Low Seismic Risk", Zone III is of "Moderate Seismic Risk", Zone IV is of "Severe Seismic Risk", & Zone V is of "Very Severe Seismic Risk".
3. **Chennai** comes under Zone III which is of "Moderate Seismic Risk".
4. Various design parameters for seismic analysis, suggested are as follows:

a. Zone factor (Z)	= 0.16
b. Importance factor for the structure (I)	= 1.2
c. Response reduction factor (R)	= 3.0
d. Soil site factor	= Medium
- Period considered for the structure is WITHOUT INFIL as per CI 7.6.2(a).
5. For calculating the earthquake force on roofs the live load shall not be considered.
6. The horizontal earthquake force shall be calculated for the full dead load and 25% of live loads.
7. The Dynamic method is used for the analysis of structure.

pal

File Name: Structural Design Philosophy	Project No: APC/22-23/4	Page Number: 10 of 15
Prepared by YOGESH	Checked By PAL	Approved By VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

APC Anagha
Prudent Consultants LLP**3.5 CONSTRUCTION MATERIALS.****3.5.1 STEEL**

All reinforcing steel shall be **Fe 550** grade with 14.5% elongation.

Y – on all drawings represents high yield strength deformed bars.

3.5.2 CONCRETE

Grade of concrete for shear walls and columns shall be as per design requirement. Grade of concrete of for beams, slabs and all other elements shall be M30. Flyash or GGBS can be replaced for concrete upto 20%.

FOUNDATION, RETAINING WALLS & OTHER CONCRETE BELOW GROUND LEVEL.

Grade of concrete for sub-structural elements shall be as per the design requirements with minimum cement content of **400 Kg/m³** for walls of liquid retaining structures. Flyash or GGBS can be replaced for concrete upto 20%.

SLAB & BEAMS

Concrete grade shall be as per the design requirement with minimum cement content of **320 Kg/m³** Flyash or GGBS can be replaced for concrete upto 20%.

MINIMUM CEMENT CONTENT:

<u>GRADE OF CONCRETE</u>	<u>MIN CEMENT CONTENT</u>
M20 & M25	300 Kg/m ³
M30	320 Kg/m ³
M35	340 Kg/m ³
M40	360 Kg/m ³
M45	380 Kg/m ³

Maximum cement content not to exceed 450 Kg/m³.

Pal

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 11 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD



Amer & Ani Architects

DESIGN PHILOSOPHY FOR STRUCTURAL DESIGN

Document No: ANAGHA/CIB

Date: 08.08.2023

R0



Prudent Consultants LLP

FOUNDATIONS

1. Pile foundation is adopted as recommended from soil investigators.
2. All loose pockets and soft spots are to be filled in mass concrete of grade M10.
3. All backfilling shall be well compacted to achieve 95% modified dry density. Compaction shall be done in layers of not more than 300mm.
4. Suggested precautions indicated in geotechnical report shall be followed while undertaking the construction activity.
5. Design of foundation / substructure shall be done as per recommendations of geotechnical investigations report and relevant codes of practice / handbooks.

PILE DETAILS:

TABLE:- 4.1 RECOMMENDED SAFE LOAD CARRYING CAPACITIES OF BORED CAST-IN SITU PILES									
S. NO	REF BOREHOLE NUMBER	LENGTH OF PILE BELOW EGL	SOCKET IN WEATHERED ROCK			DIAMETER OF PILE	SAFE LOAD CARRYING CAPACITY (kN)		
			TOP OF SOCKET	BOTTOM OF SOCKET	LENGTH OF SOCKET		VERTICAL LOAD CARRYING CAPACITY	PULL OUT CAPACITY	LATERAL LOAD CARRYING CAPACITY
1.0	BH-01	13.0	11.5	13.0	1.5	500	1250	600	Design as structural piles with fixity beyond 10.0m
2.0						600	1650	700	
3.0						750	2350	800	
4.0						800	2600	900	

3.5.3 LAP / DEVELOPMENT LENGTH

Lap / Development Length	Fe 500 for bars in Tension	Fe 500 for bars in compression
M20	57x dia.	46x dia.
M25	49x dia.	39x dia.
M30	45 x dia.	36 x dia.
M35	40 x dia.	32 x dia.
M40 & above	36x dia.	36x dia.

File Name: Structural Design Philosophy		Project No: APC/22-23/4		Page Number: 12 of 15	
Prepared by	YOGESH	Checked By	PAL	Approved By	VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN**

Document No: ANAGHA/CIB

Date: 08.08.2023

R0

**3.5.4 CONCRETE COVER**

The structures shall be designed with Clear concrete cover to reinforcement as follows:

Solid slabs	25 mm
Pile cap	75&50 mm for bottom & top respectively
Retaining Wall	30 mm on earth side
Beams	40 mm simply supported / 30mm continuous mm
Columns	40 mm
UG and OH Water tanks	30 mm on outer side / 30 mm on water side
Staircase	30 mm
Shear wall	30 mm
Grade Slab	40 mm from top

The structure is designed for 2.0 hr fire rating.

3.5.5 WATER PROOFING

Tanking membrane/Crystalline water proofing is proposed for retaining walls.

Crysatallisation/Membrane/Elastomeric cementitious coating for wet areas and Single component PU for podium and roof.

3.6 GENERAL NOTES

1. Structural drawings shall be read and used in conjunction with Architectural, Mechanical, Plumbing, Electrical drawings and project specifications.
2. Unless otherwise noted, details shown on any structural drawings are to be considered typical for all similar conditions.
3. All 'levels' to be read from Architectural drawings & corresponding services drawings.
4. All dimensions in structural drawings, reinforcing bar diameters / spacing of bars are in millimeters.
5. Exposure condition considered for the sub and super structure is moderate as per Table-3 of IS 456.
6. Cracked section properties as per Table-6 of IS-16700-2017 is adopted.

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 13 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD**DESIGN PHILOSOPHY FOR
STRUCTURAL DESIGN****Document No: ANAGHA/CIB****APC Anagha**
Prudent Consultants LLP**Date: 08.08.2023****R0****3.7 DESIGN CODES AND REFERENCES:**

Indian Standard Code of Practice for Design Loads (other than Earthquake) for buildings and structures. IS: 875 (Part 1 DEAD LOADS) 1987.

1. Indian Standard Code of Practice for Design loads (other than Earthquake) for buildings and structures. IS: 875 (Part 2 LIVE LOADS) – 1987.
2. Indian Standard Code of Practice for Design loads (other than Earthquake) for buildings and structures. IS: 875 (Part 3 WIND LOADS) – 2015.
3. Indian Standard Code of Practice for Design loads (other than Earthquake) for buildings and structures. IS: 875 (Part 5 SPECIAL LOADS & COMBINATIONS) – 1987.
4. Indian Standard Plain and Reinforced Concrete. Code of Practice. IS: 456 : 2000.
5. Indian Standard Criteria for Earthquake Resistant Design of Structures IS:1893(Part1) :2016.
6. Indian Standard code of practice for Earthquake Resistant Design and construction of buildings (2nd Revision) IS: 4326 – 1993.
7. Indian Standard Code of practice for concrete structures for the storage of liquids IS: 3370 (Part I&II) – 2009.
8. SP-16 – 1980, Design Aids for reinforced concrete to IS: 456 – 2000.
9. SP: 24 – 1983. Explanatory Hand book on Indian Standard Code of Practice for Plain and Reinforced Concrete to IS: 456 – 2000.
10. Indian standard code of practice for ductile design and detailing of reinforced concrete structure subject to seismic force IS:13920-2016.
11. Indian standard code of practice for structural safety of tall concrete building IS:16700-2017
12. Indian Standard Hand Book on Concrete Reinforcement and Detailing SP:34(S&T)–1987.
13. Foundation Analysis and Design – Joseph E Bowles – McGraw-Hill Publications.
14. Reinforced Concrete Designer's Hand Book – C.E. Reynolds and James C. Steedman.
15. Hand Book of Concrete Engineering – Mark Fintel – CBS Publishers and Distributors.
16. IS 1904-Indian Standard Code of Practice for design & construction foundation in soil general requirements.

File Name: Structural Design Philosophy

Project No: APC/22-23/4

Page Number: 14 of 15

Prepared by YOGESH

Checked By PAL

Approved
By

VGP

COVE HOLDINGS PVT LTD				
 Amer & Ani Architects	DESIGN PHILOSOPHY FOR STRUCTURAL DESIGN			
	Document No: ANAGHA/CIB			
	Date: 08.08.2023	R0		
17. IS 2950 - Indian Standard Code of Practice for design & construction of raft foundation (Part-1) 18. IS 2911 part 1 section 1 – Indoan code of practice for design & construction of Pile foundations. <i>Pal</i>				
File Name: Structural Design Philosophy		Project No: APC/22-23/4		Page Number: 15 of 15
Prepared by	YOGESH	Checked By	PAL	Approved By VGP