



Kannimar Consultants

Industrial Building Consultants
S t r u c t u r a l D e s i g n

New No. 14, Old No. 17A, Kannimar Villa, Ganga Nagar, Jafferkanpet,
Ashok Nagar, Chennai - 83. Ph. : 24749439, 94441 83538, 9500074947

S. Subramaniam, M.S. (Struc). PDQS. DRTM.

Chartered Engineer

Registered Structural Engineer Grade - I

E-mail : kannimarconsultants@gmail.com

Stability Certificate

1. The detailed engineering and structure design of the proposed building comprising of Stilt + 5 floors at 127/2A, 127/1B1 & 127/1B2 of Kalapatti West [28] Village, Coimbatore North Taluk, Coimbatore District. has been done by me/us based on the report of Geotechnical investigation (Soil test) done by Geodesign India Pvt Ltd report no: GEO-185/2024-2025 dated on 9/12/2024 and considering the functional requirement of the building.
2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We checked various parameters and found that the proposed building would be safe.
3. I/We further certify that:
 - i) The minimum grade of concrete is **M25**
 - ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS codes No **IS:875-part-2 (1987)** and design of earthquake resistant structure as per IS code No. **IS:1893:2016 part -I.**
4. The building will be safe and sound when used for the purpose for which it is designed.

Stamp and Signature

S. Subramaniam, M.S. (Struc)., PDQS, DRTM.
Registered Structural Engineer Grade - I,
CGLDIST / SE / Gr-I / 2019 / 05 / 006
New No. 14, Old No. 17A, Kannimar Villa,
Ganga Nagar, Jafferkanpet, Ashok Nagar,
Chennai - 83. PH : 044 - 2474 9439, 95000 74947
kannimarconsultants@gmail.com