


STABILITY CERTIFICATE

The detailed engineering and structure design of the proposed Stilt + 3 Floors Residential building units "MP RUE RADIALE PH-1" 12 blocks with 72 dwelling Owned by **M/s. MP DEVELOPERS AND CONSTRUCTIONS PRIVATE LIMITED** Comprised in Plot no 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18 19, 20, 21, 22, 23 & 24, TS No.6/3 & 6/8 Block 25, Ward No G, S no 37 & 38/1, Nemilichery Village, Pallavaram Taluk, Chengalpattu District has been done by me based on the report of geotechnical investigation done by **DYNAMIQ ENGINEERING RESEARCH CENTRE** Report No 3382 dated 23/05/2026 and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I have checked various parameters and found that the proposed building would be safe.

3. I further certify that: (i) The minimum grade of concrete is M20 (ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS 875 Part I to V and design of earthquake resistant structure for Seismic Zone III as per IS 1893 (Part-I)-2016

4. The building will be safe and sound when used for the purpose for which it is designed.


A.N.MAGESH RAJA, M.E., (Structural Engineer)
CMDA/GCC REGISTERED STRUCTURAL ENGINEER GRADE-I (RSE)
CMDA REG.No:SE/GR-I/2022/06/325
GCC REG.No:RSE101432021
CELL:97870 72100
magiststructure@gmail.com