



DATE: 24-09-2025

STABILITY CERTIFICATE

The detailed engineering and structure design of the Proposed Construction of a Stilt Floor Parking / Ground Floor Part Kids Play Area + 5 Floors Residential Building, 18.30m - Height with 314 Dwelling Units Availing Premium FSI (1st Floor - 61 Dwelling Units, Swimming Pool, Kids Play Area, Indoor Games, Video Games, Association Room, and Creche + 2nd Floor - 61 Dwelling Units, Home Theatre, Gym, Buisness Center, Yoga, Study Room and Association Room + 3rd To 5th Floor - Each Floor 64 Dwelling Units) at Puzhal Village Comprised In S.Nos.31, 32, 33 and 34 of Puzhal Village within the Limits of Greater Chennai Corporation has been done by me/us based on the report of geotechnical investigation (soil test) done by Geo Mines Engineers Pvt. Ltd. Report No. GMEPL/SILVERSKY BUILDERS/479/2023-24 Dated 19-01-2024 and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We have checked various parameters and found that the proposed building would be safe.

3. I/We further certify that:

(i) The minimum grade of concrete is M25.

(ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS Codes No IS-875 and design of earthquake resistant structure as per IS Code No IS-1893 & IS-13920.

4. The building will be safe and sound when used for the purpose for which it is designed.

Stamp and Signature

Dr. J. SURESH, M.E., MIE., Ph.D.

Structural Engineer

Plot No. 555, VGP Layout, Mullai Street,
Uthandi, Chennai - 600 119.

Reg. No. SE/I/2024/2/0014

Reg. No. RSE100382019

Reg. No. CGLDIST/SE/Gr-I/2024/07/005

Encl.: Structural Design Calculation



044 - 2445 5666
+91 893939 7479
+91 893939 7579



www.universalconsultants.net
suresh@universalconsultants.net



New. No. 2/4, First Cross Street,
Indira Nagar, Adyar, Chennai - 600 020.