

STABILITY CERTIFICATE

Date: 8/9/2025

The detailed engineering and structural design of the proposed building comprising of Stilt Floor + 4 floors Residential Building (Height-14.00m) With 32 Dwelling Units At Plot No.A-2 & A-3, S.No.11/4 & 11/5, at (DTCP Approved Layout No.239/92) Gokul Nagar, Rangopanditha Agraharam Village, with in the Limits of Onnalvadi Panchayat, Hosur Panchayat Union & Taluk, Krishnagiri Dt. has been done by me **(Mr.J.ANANDSUBASH)** based on the report of geotechnical investigation done by.

M/S UNIVERSAL LAND SURVEYORS & SOIL TESTING LABD Report No.

C-7676-ST-5184 ,Dated **06/09/2025** and considering the functional requirement of the building.


2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I have checked various parameters and found that the proposed building would be safe.

3. I further certify that:

(i) The minimum grade of concrete is M 25

(ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS Codes No IS-875 and design of earthquake resistant structure as per IS Code No 1893.

4. The building will be safe and sound when used for the purpose for which it is designed.


Stamp and Signature

Encl.: Structural Design Calculation

Focus8 PROPERTIES**Er. J. ANAND SUBASH, M.Tech (Structures)****Consulting Civil Engineer & Contractor**

Govt. Regd. Engineer Grade -1, (RE), HNTDA No. 03/2019,

Govt. Structural Engineer Grade -1, (SE) HNTDA No. 03/2019

M. 144, TNHB-IX, Opp. Railway Station, Hosur - 635 109.

Cell : 95852 32417, Mani - 99443 36388.