

72, 3rd Floor,
(Above Canara Bank),
50 Feet Road,
Hanumanthanagar,
Bengaluru - 560 019

Telefax : 080 - 26615806
Mobile : 080 - 26615806
E-mail : info@visda.co.in
Website : www.visda.co.in

STABILITY CERTIFICATE

Dated -12.02.2026

The detailed engineering and structure design of the Proposed Residential Group Development, Blocks 1 to 12, as detailed below

Block No.	G + 1 Floor No of units	G + 2 Floor No of units
1	2	
2	2	
3	4	
4	20	
5	6	
6	10	
7	14	
8	3	5
9	8	
10	10	
11	1	
12	1	6
Total	81nos	11nos
Grand Total	92 nos	

72, 3rd Floor,
(Above Canara Bank),
50 Feet Road,
Hanumanthanagar,
Bengaluru - 560 019

Telefax : 080 - 26615806
Mobile : 080 - 26615806
E-mail : info@visda.co.in
Website : www.visda.co.in

comprised in S.Nos. 190/13B2, 14B2, 15A, 15B, 16A1, 16B1, 16B2, 16B3, 192/1A, 1B, 2, 10, 193/1A1A, 1B & 9A1 in Pudupakkam Village, Vandalur Taluk in Chengalpattu District, has been done by me/us based on the report of geotechnical investigation (soil test) done by M/s Falcon Industrial Testing Lab Pvt. Ltd. Report No. Falcon/GIR/TR2404043 Dated - 09/05/2024 and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We have checked various parameters and found that the proposed building would be safe.

3. I/We further certify that:

(i) The minimum grade of concrete is:- M 30.

(ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS 875-Part 2 and design of earthquake resistant structure as per IS 1893:2016 and Wind analysis as per IS 875-Part 3 and detailing is done as per IS 13920 : 2016.

4. The building will be safe and sound when used for the purpose for which it is designed.


AMAR NATH. R. BORAI AH M.Tech
Registered Structural Engineering Grade-1 (RSE)
Reg. No. TVLR/RSE/Gr-I/2023/02/004
17, C-Block, R.V. Nagar, Ashoknagar,
Chennai-83. Ph: 97313 03187

Stamp and Signature

Encl.: Structural Design Calculation