STABILITY CERTIFICATE

1.The detailed engineering and structure design of the proposed building comprising of Blocks F, G, H, J, K, L, M with 1 Basement +1 stilt+28 floors and Block N with 1 Basement + 1 stilt+16 floors at Chennai S.Nos. 93,94,95,96,97, 100, 101,102,103/1A2,116/1B,117/2A1,2A2,2B, 118/2B12,2B13,131/23 and 131/4 of Arasankalani village and S.Nos. 443/2, 444/1 and 444/2 of Perumbakkam village has been done by me/us based on the report of geotechnical investigation (soil test) done by M/S F.S Engineers Pvt Ltd Report No. 6031 Dated 19th may 2015 and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We have checked various parameters and found that the proposed building would be safe.

3. I/We further certify that:
   - The minimum grade of concrete is M30
   - The design and analysis have been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS Codes No IS 875 and design of earthquake resistant structure as per IS Code No IS 1893(part-1)-2016 & IS 16700-2023

4. The building will be safe and sound when used for the purpose for which it is designed.

For Innotech Engineering Consult Pvt Ltd

H.P. Yogesh
Join Managing Director
Registered Structural Engineer Grade-I (SE)
Registration No.SE/GR-I/19/03/022

H.P. YOGESH
B.E. (Civil), M.Tech (Structure)
Registration No. SE/GR-I/19/03/022
Structural Engineer Grade-I (SE)
Mobile : +91 97413 99608