



CHENNAI METROPOLITAN DEVELOPMENT AUTHORITY  
'ThalamuthuNatarajan Building', No.1, Gandhi Irwin Road,  
Egmore, Chennai-600 008.

## PROFESSIONAL REGISTRATION CERTIFICATE

This is to certify that the **Thiru. A. VEERAPPAN** has enrolled as **Registered Structural Engineer Grade-I (SE)** with Chennai Metropolitan Development Authority (CMDA) who has the qualification of **M.E., (Structural Engg.)** and experience in the relevant field for **40 years**.

He has been given the Registration No.**SE/GR-I/2019/05/113** Renewed on **02.05.2024**. He shall be required to comply with the duties and responsibilities prescribed by the Government of Tamil Nadu in Part-V, "Registration of Professionals", Tamil Nadu Combined Development and Building Rules, 2019 approved vide G.O.(Ms) No.18 MAWS (MA1) Dept. dated 04.02.2019.

This Registration is valid upto **01.05.2029**.



*[Signature]*  
**(A. MEGANATHAN)**  
Superintendent

*[Signature]*  
VN

**Er.Dr.A.VEERAPPAN** ME(Struct), Ph.D, FIE, MICI, Dip in LL & AL,  
New No.36, Valluvar Road, TSD Nagar  
Arumbakkam, Chennai - 600 106.  
☎ (0) 7200000000  
email: [veerappan@cmda.org](mailto:veerappan@cmda.org) com



**Er. A. VEERAPPAN & ASSOCIATES**

**(TAMIL NADU) PRIVATE LTD**

**Engineers Designers & Structural Consultants**

**Er. Dr. A. Veerappan, M.E (Struct), Ph.D (Struct) P.E, M.E.D, Dip. LL & AL - Managing Director**

09-03-2026

**STABILITY CERTIFICATE**

(To be furnished while filing application for registration of building)

The detailed engineering and structure design of the proposed building comprising of **Residential Apartments Stilt+5floors at Plot No. 26, 27 & 28, EVP Sri Ram Nagar at Nolambur, Chennai S.No. 206 / 9A & 9B** has been done by us based on the report of geotechnical investigation (soil test) done by **Globe Geotechniques** Report No. **GS / APR 25 - TN 290 - Nolambur** dated **19-01-2024** and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. We have checked various parameters and found that the proposed building would be safe.
3. We further certify that:
  - (i) The minimum grade of concrete is **M25**
  - (ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS Codes No **875-1987** and design of earthquake resistant structure as per IS Code No **1893 -2016**
4. The building will be safe and sound when used for the purpose for which it is designed.

Stamp and Signature  
09-03-2026

Er. Dr. A. VEERAPPAN M.E (Struct), Ph.D (Struct), P.E, M.E.D, Dip. LL & AL.  
Now No. 36, Valluvar Road, TSD Nagar  
Arumbakkam, Chennai - 600 106.  
☎ (0) 72000 79289  
email : er\_a\_veerappan@hotmail.com

Encl.: Structural Design Calculation