

AME STRUCTURAL CONSULTANTS

25.03.2026

STABILITY CERTIFICATE

(To be furnished while filing application for registration of building)


1. The detailed engineering and structure design of the Proposed construction of Group Housing Development With 4 Blocks, Block A – Stilt Floor + 3 Floors + 4th Floor (Part) + 5th Floor (Part) (Height – 18.0m) Residential Building With 19 Dwelling Units And Association Room, Yoga Room, Kids Play Room, Library, GYM and Swimming Pool at 5th Floor Level; Block B – Stilt Floor + 5 Floors (Height – 18.0m) Residential Building With 33 Dwelling Units; Block C – Stilt Floor + 4 Floors + 5th Floor (Part) (Height – 18.0m) Residential Building With 38 Dwelling Units; Block D – Stilt Floor + 4 Floors (Height – 15.0m) Residential Building With 32 Dwelling Units; Totally 122 Dwelling Unit at Madambakkam, Chennai in S.No.716/1D1, 716/1D2, 716/3, 716/4 & 716/5 of Madambakkam Village, Tambaram Taluk, Chengalpattu District Within The Limit of Tambaram Municipal Corporation has been done by me/us (**A.N.MAGESH RAJA**) based on the report of geotechnical investigation (soil test) done by **R. VENKATA KRISHNAIAH** Report No.: VCE/23/GIR-011, Dated 10/05/2023 and considering the functional requirement of the building.
2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We have checked various parameters and found that the proposed building would be safe.
3. I/We. Further certify that
 - (i) The minimum grade of concrete is M30, Fe500 and Fe550 Steel
 - (ii) The design and analysis has been done using the code of practice for plan and reinforced concrete as per IS 456, design loads as per IS Code No IS-875 and design of earthquake resistant structure as per IS Code No 1893.
4. The building will be safe and sound when used for the purpose for which it is designed.

Er. MAGESHRAJAA. N M.E Struc.
AME Structural Consultants

Encl.: Structural Design Calculation

AME STRUCTURAL CONSULTANTS

No. 28, Jawaharlal Nehru St,
Perungalathur, Chennai - 600 063, India
+91-9840127487
www.amestructuralconsultants.com,
Email:amestructuralconsultants@gmail.com


A.N.MAGESH RAJA, M.E., (Structural Engineer)
CMDA/GCC REGISTERED STRUCTURAL ENGINEER GRADE-III (RSE)
CMDA REG.No:SE/GR-I/2022/06/325
GCC REG.No:RSE101432021
CELL:97870 72100
magistructure@gmail.com



CHENNAI METROPOLITAN DEVELOPMENT AUTHORITY
'Thalamuthu Natarajan Building', No.1, Gandhi Irwin Road,
Egmore, Chennai-600 008.

PROFESSIONAL REGISTRATION CERTIFICATE

This is to certify that **Thiru. MAGESHRAJAA. N** has enrolled as **Registered Structural Engineer Grade-I (SE)** with Chennai Metropolitan Development Authority (CMDA) who has the qualification of **M.E., (Structural Engg.)** and experience in the relevant field for **8 years**.

He has been given the Registration No.**SE/GR-I/2022/06/325** on **24.06.2022**. He shall be required to comply with the duties and responsibilities prescribed by the Government of Tamil Nadu in Part-V, "Registration of Professionals", Tamil Nadu Combined Development and Building Rules, 2019 approved vide G.O.(Ms) No.18 MAWS (MA1) Dept. dated 04.02.2019.

This Registration is valid upto **23.06.2027**.



Magesh Raja
A.N. MAGESH RAJA, M.E.,
CMDA Registered Structural Engineer Grade-I (RSE)
Reg.No: SE/GR-I/2022/06/325
Cell: 97870 72100
mageshstructure@gmail.com

A. MEGANATHAN
(A. MEGANATHAN)
Superintendent