

STABILITY CERTIFICATE

(To be furnished while filing application for registration of building)

1. The detailed engineering and structure design of the proposed building comprising of Stilt floor + Three floor Residential Building At Door No 152, Mettu Street, Ayanavaram, Chennai-23, Anna Nagar Sub Registration District, T.S.No. 84, Blockno 28, Paimash No 980 Of Ayanavaram Village With In The Limits Of Greater Chennai Corporation has been done by me based on the report of geotechnical investigation (soil test) done by **Er. A. Nivedhitha (Booshnam Associates) Report No. BAG/Mr. PRAVEEN KUMAR/BAGJ-2137/25-26 Dated-07-07-2025** and considering the functional requirement of the building.
2. It is certified that among other factors, the proposed building has been designed to resist earthquake, I have checked various parameters and found that the proposed building would be safe.
3. I further certify that:
 - (i) The minimum grade of concrete is **M30**.
 - (ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS **456:2000**, design loads as per IS Codes No **875**, and design of earthquake resistant structure as per IS Code No **1893:2016**.
4. The Building will be safe and sound when used for the purpose for which it is designed.

Date: 11.02.2026
Place: Chennai

Stamp and Signature

T.BHARANITHARAN, M.E., C.Eng(I).
Registered Civil & Structural Engineer., CMDA
REGD NO: (RE/GR-I/19/05/166) & (SE/GR-II/19/04/036)
KURAL ASSOCIATES
No. 3/1517, Mugalivakkam Main Road,
Madhanandapuram, Porur, Chennai-600125.
Mob: 9791776685 / Tel No: 044-79670563

Flat No. G1, Anusha Garden, BLOCK A,
Plot No.VII, Annai Velankanni Nagar, Madhanandapuram, Chennai - 600125.
kuralassociates.engineers@gmail.com

044 79670563 | /kuralassociates