

STABILITY CERTIFICATE

The detailed engineering and structure design of the proposed building comprising

named " Infinium Onelife" by M/s Infinium Reality Comprising of Combined basement floor Block A (Ground Floor + 5 floors), Block B (Ground Floor + 5 floors), Block C (Ground Floor + 5 floors), Block D (Ground Floor + 3 floors), Block E (Ground Floor + 1 floors) , Block F Ground floor with watchman room altogether with 156 Dwelling units SF No 188/1, At Vedapatti Village and Town panchayat, Perur Taluk, Coimbatore district has been done by me/us based on the report of geotechnical investigation (soil test) done by Geo engineering Consultants Report No GEC-JC-GT-7028/2025-26 Dated 18/07/2025 and considering the functional requirement of the building.

2. It is certified that among other factors, the proposed building has been designed to resist earthquake. I/We have checked various parameters and found that the proposed building would be safe.

3. I/We further certify that:

(i) The minimum grade of concrete is M30

(ii) The design and analysis has been done using the code of practice for plain and reinforced concrete as per IS 456, design loads as per IS Codes No 875 and design of earthquake resistant structure as per IS Code No 1893

4. The building will be safe and sound when used for the purpose for which it is designed.



Structural Engineer (V.G.Palaksha)
CGLRGN/SE/Gr-I/2019/07/023

V.G. PALAKSHA
DTCP Reg. No.:
CGLRGN/SE/Gr-I/2019/07/023